Public Works

MONTHLY REPORT

March, 2026

FIVE RIVERS

Authored by:

Joshua Gallant – Public Works

March 2026

Public Works REPORT

Rexton Sports & Recreation Centre

- **Curling open**
- **Check ice plant daily**
- **Schedule the 30hp motor replacement and refill R448A refrigerant also proceed with plant shut down for the end of the season.**

Splash Pad

- **Closed for the season**
- **Check daily**

Carson's Landing

- **Closed for the season**
- **Check daily**

Bonar Law Common

- **Closed for the season**
- **Check daily**
- **Kept a fire lane open for winter**

Community Garden

- **Close for the season**

Lift station and lagoon

- **Check all 8-lift station daily and lagoon**
- **the annual wastewater report has been finalized, indicating that we received 238,506 cubic meters of wastewater into the Rexton lagoon. In the previous years the volume was 925,000 cubic meters.**
- **The average CBOD concentration in the effluent is 30MG/L per year. According to the approval to operate we must maintain a level below 25MG/L of CBOD.**
- **The average concentration of suspended solids in the effluent 43.25 MG/L per year.**
- **According to the approval to operate we must maintain a level below 25 MG/L.**
- **We passed the acutely lethal toxicity test with 30% mortality out of 10 fish in a period of 24hour. According to the approval to operate 100% mortality we would have failed the test.**

- **We will need to acquire a john boat in order to proceed with the sludge surveying, as well as to implement scum control, manage aquatic weed control, and to inspect for any signs of erosion and leaks. The estimated cost is 3873.20$ including tax.**

Current Projects

- **Lagoon (awaiting favorable weather condition for sludge surveying)**
- **We will obtain an estimated cost for the Lions Club roof.**
- **A Mini split will be installed in the council chambers.**
- **Signs for Municipal Office and Public Works building have been designed and will be sent for print in the coming weeks.**

Parks/Walking Trails

- **Regular maintenance**
- **Regular daily checks**
- **Clear snow after every snow storm**

Other

- **There was a problem with the emergency lights in the Rexton ambulance bay. The lights have been fixed.**
- **The crosswalk light located in front of the municipal office required repairs once more.**
- **The technician indicated that it appeared a rodent had entered the pole and damage the wiring**
- **The man hole on Albany Street has been repaired.**
- **Engaged in green shore training.**
- **We preformed some cold patching around Rexton, utilizing 1650 pound of cold patch material**
- **Serviced all summer equipment**